

A sample of the following product has been tested and is stated by Nemko to be in conformity with the applicable European standards referred below.

Product Heating elements for building into floors
Manufacturer OPUS ICI Group Ltd.
1 Panagron Street
2571 Nisou
Cyprus
Factory OPUS ICI Group Ltd.
1 Panagron Street
2571 Nisou
Cyprus
☐ See next page(s)
Ratings Max. 180W/m², 94-504W
0.40-2.19A 220-240V~ or 110-120V~ or 48V~ or 24V~
Trade mark



Model / Type Ref. ATBBUIRCVPLLWW

Principal characteristics ☒ See page 2

A sample of the product was tested and found to be in conformity with
HOUS EN 60335-1:2002;A11;A1;A12;A2;A13;A14
EMF EN 60335-2-96:2002;A1;A2
EN 50366:2003;A1

Test Report Ref. No. 144977

It may therefore be presumed that the tested sample of the product is in conformity with the technical provisions of the following European Directives including the latest amendments, and with national legislation implementing these Directives:

- Low Voltage Directive 2006/95/EC

Provided that other applicable Directive requirements are satisfied, the manufacturer (or the European authorized representative), may draw up an EC/EEA Declaration of Conformity and affix the CE-marking to each conforming product.

Additional model(s) ☐ See next page(s)

Additional information ☐ See next page(s)

Date of issue 03-02-2011



Signature

Skule Moe

Certification Department

Nemko AS

Office address

Internet

Telephone

Fax

P.O. Box 73, Blindern

Gaustadalléen 30

www.nemko.com

+47 22 96 03 30

+ 47 22 96 05 50

N-0314 Oslo, Norway

Oslo

Enterprise number:

NO 974404532

Principal characteristics

Cl. II. IPX7 permanent connection.

Explanation of model name:

BB: codes for packaging (1-99)

U: 1 = metric units or 2 = imperial units (refers to LL and WW)

I: letters for language of instructions etc – e.g. E = English, F = French, H = Hebrew

R: width of heating element ribbon in mm – from 1-8 (meaning 7 to 25mm)

C: cold wire length : 1-9

V: rated voltage, where 1 means 220-240V, 2 = 110-120V, 3 = 24V and 4 = 48V

P: specific input in W/m² – codes: 1 = 100, 2 = 120, 3 = 150 and 4 = 180

LL: length of heating mat

WW: width of heating mat

Date of issue 03-02-2011



Signature

Skule Moe

Certification Department

Nemko AS

Office address

Internet

Telephone

Fax

P.O. Box 73, Blindern

Gaustadalléen 30

www.nemko.com

+47 22 96 03 30

+ 47 22 96 05 50

N-0314 Oslo, Norway

Oslo

Enterprise number:

NO 974404532